

LOCATION 904 EDGEWOOD CIR. CITY Past.
BETWEEN Eight Ave. STREET & Ninth St. STREET

	SIZE	TYPE ..	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>?</u>	<u>84'</u>			<u>4-4-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>41'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>43'</u>			

ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 190' from ⓐ of
Ninth St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D/H/f

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH. 3 FT. 0 IN LOCATION West side of Edgewood Cir.

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY