

LOCATION 907 EDGEWOOD CIR. CITY EAST.
BETWEEN Ninth St. STREET & EIGHT AVE. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>72'</u>		<u>4-3-57</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>9'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>63'</u>			


ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 9' from @ of Ninth St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DNF
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1957

DEPTH: 3 FT. 0 IN LOCATION West side of Edgewood cir

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY