

LOCATION 1008 Edgewood Circle CITY Carstonia  
BETWEEN 10th STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>22'</u>	<u>Relocated</u>		
MAIN TO PROP LINE					<u>3-26-89</u>	
PROP LINE TO BLDG						

ENTERS 1008 BRANCHED INTO 0

TAP SIZE 3/4 IN. PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION

PRESSURE TEST 100 PSI FOR 1/4 HRS BY EP

MAIN SIZE 3/4 CI \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED \_\_\_\_\_

DEPTH 1 FT 6 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# 17 # \_\_\_\_\_ LR # \_\_\_\_\_

REMARKS  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>Positive</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	

