

LOCATION 1008 EDGEWOOD CIR CITY CAS.
BETWEEN Tenth Ave. STREET & Ninth Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>114'</u>			<u>4-4-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>23'</u>			

ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 102' From @ of
Tenth Ave.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DAH

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN. LOCATION West side of Edgewood Cir.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY