

LOCATION 1507 Edgewood Rd. CITY Canton  
BETWEEN Gamble Ave. STREET & Annadell Ave. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>87'</u>	<u>4-11-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>77'</u>			

ENTERS 5017 BRANCHED INTO  
TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 62' N. of center of Gamble Ave.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.L.K.  
MAIN-SIZE 4" C I        BARE STEEL        COATED STEEL ✓ PLASTIC        YEAR INSTALLED 1964  
DEPTH 3 FT 0 IN LOCATION 13' E. of center of Edgewood Rd.

"A" P/S READING 1.4 TOTAL ANODES 1# 0 17# 0 LR # 316940

REMARKS

	Test Station	
	Reading & Location	Lead
	P/S Pipeline Lead - Red New Service	<u>S</u>
	P/S Pipeline Lead - White Existing Main	<u>E</u>