

LOCATION

1511 Edgewood Rd.

CITY

GASTONIA

BETWEEN

STREET &amp;

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	64'	10-16-95		
MAIN TO PROP. LINE	3/4	Plastic	17'			
PROP. LINE TO BLDG.	3/4	Plastic	47'			

ENTERS: 1511

BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 10' S of 1st of Sandle St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1964

DEPTH: 3 Ft. 0 In. LOCATION 14' E of 1st of Edgewood Rd.

"A" P/S READING 1.4 TOTAL ANODES 1# 17# L.R. # 508036

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Rise Plastic
P/S Pipeline Lead - White Existing Main	E	