

LOCATION 1530 Edgewood Rd. CITY CANTONIA

BETWEEN Delmont Ct. STREET & SEA OATS LN. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG. | 3/4" | P | 131' | 9-17-98 | | |
| MAIN TO PROP LINE | 3/4" | P | 35' | | | |
| PROP. LINE TO BLDG. | 3/4" | P | 96' | | | |

ENTERS: 1530 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 210' N. of center of

Delmont Ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S. HURTSLETTER

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 3 FT 0 IN LOCATION 15' E. of center of Edgewood Rd.

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 L.R. # 2034533

REMARKS:



| Test Station | | |
|--|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY