

LOCATION 802 Apt. "C" 802 Edwards St. AVE. CITY Gastonia  
 BETWEEN Church STREET & Dead end STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>150</u>	<u>3-27-96</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>35</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>1.15</u>			

ENTERS: 802 Apt C BRANCHED INTO: 0  
 TAP SIZE: 3/4 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 2162' W of C of Church

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BC  
 MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996  
 DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION 10' S of C of Edwards

"A" P/S READING Plastic TOTAL ANODES 1\* - 17\* - L.R. # 00143834

REMARKS:  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY