

LOCATION 411 E 1st St.

CITY GASTONIA

BETWEEN Rolling Meadows

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RELOCATED	RENEWED
MAIN TO BLDG.	3/4	C/W	6'		2-9-96	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 411

BRANCHED INTO:

TAP SIZE: 3/4

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 84' S. of cor

E 1st St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By [Signature]

MAIN - SIZE 3/4 C.I. — BARE STEEL — COATED STEEL ☒ PLASTIC — YEAR INSTALLED —

DEPTH: 1 Ft. 6 In. LOCATION

"A" P/S READING — TOTAL ANODES 1# 1 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	SR	1.60
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY