

LOCATION 505 E. 8TH AVE. CITY EAST.

BETWEEN Union Rd. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>148'</u>			<u>2-11-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>36'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>112'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 738' From (N) of Union Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY W.H.J.

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN. LOCATION north side of E. 8TH AVE.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY