

LOCATION 601 E 8TH AVE CITY FAST.
BETWEEN Dead End STREET & Union Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>40'</u>			<u>2-19-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>1'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>39'</u>			

ENTERS: SAME BRANCHED INTO: 603 E 8TH AVE

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 375' From Dead end


PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY N/A

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN LOCATION North side of E. 8TH AVE.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY