

LOCATION 1003 EIGHT AVE. CITY EAST.  
BETWEEN DOGWOOD STREET & LAUREL LN. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>91'</u>		<u>11-</u>	<u>7-97</u>
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>84'</u>			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION S. OF 8TH AVE.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY