

LOCATION 1035 E 8th Ave CITY Gastonia
BETWEEN Laurel Ln STREET & Reid STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>95'</u>		<u>52' of 3/4" BARE</u>	<u>12-16-94</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>44'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>51'</u>			

ENTERS: 1035 E 8th BRANCHED INTO: —
TAP SIZE: 3/8 PRESSURE 60 P.S.I. — INCHES W.C. LOCATION 23' N of 8th Ave

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By S. Elmore
MAIN-SIZE 4" C.I. — BARE STEEL — COATED STEEL — PLASTIC — YEAR INSTALLED 1959
DEPTH: 3 Ft. 6 In. LOCATION 22' E of Laurel Ln

"A" P/S READING 1.7 TOTAL ANODES 1* 17* — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY