

LOCATION 210 W. 8TH AVE. CITY EAST
BETWEEN SOUTH ST. STREET & FIBBONS ST. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>105'</u>			<u>3-21-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>43'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>60'</u>			

ENTERS. SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 100' from (C) OF SOUTH ST.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY AM

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH. 3 FT 0 IN LOCATION SOUTH SIDE OF 8TH AVE.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY