

LOCATION 296B Elder Ct. CITY GASTONIA
 BETWEEN Kennett Ave. STREET & End of Calderack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>16'</u>	<u>6/27/00</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>12'</u>			

ENTERS 2974 BRANCHED INTO, 0
 TAP SIZE 3/4 3WAY PRESSURE 60 PSI INCHES WC LOCATION 290' E of C of Kennett Ave.
P. Tee


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

Service SIZE 3/4 C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 2 FT 0 IN LOCATION 90' S of C of Elder Ct.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 LR # 00487274

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>