

LOCATION 2969 Elder St CITY Crofton, MD
 BETWEEN Kennett STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>112'</u>	<u>8-9-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>107'</u>			

 ENTERS 2969 BRANCHED INTO 0
 TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION

PRESSURE TEST 100 PSI FOR 1 1/4 HRS BY EP
 MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998
 DEPTH 3 FT 0 IN LOCATION

"A" P/S READING 9 TOTAL ANODES 1# 17# LR #
 REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>0.105V</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	

