

LOCATION 2986 Elder CT CITY Gastonia

BETWEEN Kennell Ave STREET & Coltsack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>104'</u>	<u>7-31-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>69'</u>			

ENTERS _____ BRANCHED INTO _____

TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES WC LOCATION 169' N of C of
Kennell Ave


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY J.S.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 21' W of C of Elder CT

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Notes
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>