

LOCATION 2993 Elder Ct CITY Castonville

BETWEEN Kennett Ave STREET & Coul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>75'</u>	<u>3-9-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>70'</u>			

ENTERS 2993 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 37' N. of center of Kennett Ave.


PRESSURE TEST @ 100 PSI FOR 4 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH: 3 FT 0 IN LOCATION 20' W. of center of Elder Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 179907

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	