

LOCATION 1264 ELGIN CT CITY CASTONIA
 BETWEEN PLANTATION TRAIL STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>106'</u>	<u>8-22-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>61'</u>			

ENTERS: 1264 BRANCHED INTO: 0
 TAP SIZE: 1/2 PRESSURE 60 P.S.I. 0 INCHES W.C. LOCATION 20' S of C of ELGIN CT.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By R.R.

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION 130' E of C of PLANTATION TRAIL

"A" P/S READING PLASTIC TOTAL ANODES 1* 0 17* 0 L.R. # 453134

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	PLASTIC
P/S Pipeline Lead - White Existing Main	E	Riser

ENG. DEPT. USE ONLY