

LOCATION 1270 ELGIN CT. CITY GASTONIA

BETWEEN PLANTATION TRC. STREET & CAL-DE-SAC STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>133'</u>	<u>3-4-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>88'</u>			

ENTERS: 1270 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 273' E. of center of

PLANTATION TRC.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffstetter

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION 18' N. of center of ELGIN CT.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 97082

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY