

LOCATION 1278 Elgin Ct CITY GASTON, NC

BETWEEN Plantation Trl. STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>79'</u>	<u>1-21-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>74'</u>			

ENTERS: 1278 BRANCHED INTO:

TAP SIZE. 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 360' S. of center of

Plantation Trl.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstetler

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 3 FT 0 IN. LOCATION 35' E. of center of Elgin Ct

"A" P/S READING P TOTAL ANODES 1# 8 17# 0 L.R. # 26603

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY