

LOCATION 409 S. Elizabeth St. CITY Gastonia
BETWEEN Maple Ave STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	61'	12-6-01		
MAIN TO PROP LINE	5/8"	P	0			
PROP LINE TO BLDG	5/8"	P	61'			

ENTERS 409 BRANCHED INTO
TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 297' N. of center of Maple Ave.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.
MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1989
DEPTH 3 FT 0 IN LOCATION 18' W. of center of S. Elizabeth St.

"A" P/S READING P TOTAL ANODES' 1# 0 17# 0 LR # 140709

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	