

LOCATION 1515 Elkhart Cir. CITY Boston
BETWEEN Old Well Ln. STREET - & Colony Woods Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	95'	7-24-02		
MAIN TO PROP LINE	5/8"	P	45'	"		
PROP LINE TO BLDG	5/8"	P	50'	"		

ENTERS 1515 BRANCHED INTO 0
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 306 West of


center of Elkhart Cir.
PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woods

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3' FT 0" IN LOCATION 20' south of center of Elkhart Cir.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 00179705

REMARKS New Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	plastic rise
P/S Pipeline Lead White Existing Main	E	