


LOCATION	1518 EIKHART CIR			CITY	GASTONIA	
BETWEEN	Hoffman Rd.			STREET &	EIKHART CIR.	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	85'	7-26-00		
MAIN TO PROP LINE	3/4"	P	5'			
PROP LINE TO BLDG	3/4"	P	80'			
ENTERS	1518			BRANCHED INTO		
TAP SIZE	3/4"	PRESSURE	60 PSI	INCHES W C	LOCATION 294' N. of center of EIKHART CIR.	
PRESSURE TEST @	100	PSI	FOR 1/4	HRS	BY S.H.	
MAIN-SIZE	2"	C I	BARE STEEL	COATED STEEL	PLASTIC	YEAR INSTALLED 1998
DEPTH	3 FT	0 IN	LOCATION 19' W. of center of EIKHART CIR.			
"A" P/S READING	P			TOTAL ANODES 1#	0	17# 0
				LR #	652157	
REMARKS						



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	