

LOCATION 1530 ELKHART Circle CITY CASLOMIA
BETWEEN ELKHART Cir STREET & ELKHART Circle STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>84'</u>	<u>8-6-59</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>79'</u>			

ENTERS 1530 BRANCHED INTO D
TAP SIZE 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION

PRESSURE TEST 100 PSI FOR 1/4 HRS BY EP

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1958

DEPTH 3 FT 0 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# 17# LR #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>PIASTAL</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	

