

LOCATION 1542 Elkheart Cir CITY Gastonia

BETWEEN Hoffman Rd. STREET & Elkheart Cir STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>105'</u>	<u>8-23-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>65'</u>			

ENTERS 1542 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 168' S. of center of Elkheart Cir.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1989

DEPTH 3 FT 0 IN LOCATION 19' W. of center of Elkheart Cir

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 756 Bq

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	