

LOCATION 1543 Elkhardt Cir. CITY GASTONIA
BETWEEN Hoffman Rd. STREET & Elkhardt Cir. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>71'</u>	<u>2-9-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>66'</u>			

ENTERS 1543 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 135' S. of center of Elkhardt Cir.

PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH 3 FT 0 IN LOCATION 20' W. of center of Elkhardt Cir

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 97141

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

