


LOCATION	1563 Elkhamt Cir.		CITY	Gastonia		
BETWEEN	Elkhamt Cir.	STREET &	Holfman Rd.	STREET		
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	83'	5-21-01		
MAIN TO PROP LINE	3/4"	P	10'			
PROP LINE TO BLDG	3/4"	P	73'			
ENTERS	1563		BRANCHED INTO			
TAP SIZE	3/4"	PRESSURE	60 PSI	INCHES W C	LOCATION 563' W. of center of Elkhamt Cir.	
PRESSURE TEST @	100	PSI	FOR	14	HRS	BY S.H.
MAIN-SIZE	2"	C I	BARE STEEL	COATED STEEL	PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED 1998
DEPTH	3 FT	0 IN	LOCATION 52' S. of center of Elkhamt Cir.			
"A" P/S READING	P		TOTAL ANODES 1#	0	17#	0
REMARKS	LR # 391052					



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	