

LOCATION 1575 Elkhart Cir CITY GASTON, IA
BETWEEN Old Well Ln. STREET & Colony Woods Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	63'	3-19-02		
MAIN TO PROP LINE	5/8"	P	5'	"		
PROP LINE TO BLDG	5/8"	P	58'	"		

ENTERS 1575 BRANCHED INTO •

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 450 West

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY of center of Elkhart Cir.
D. W. [signature]

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH 3' FT 0" IN LOCATION 19' south of center of Elkhart Cir.

"A" P/S READING 17/17 TOTAL ANODES 1# 6 17# 6 LR # A0121943

REMARKS plastic service

Main White	Service Red	Test Station		
		Reading & Location	Lead	Volts
N ⊖ E ⊖ A ⊖	S ⊖ W ⊖ A ⊖	P/S Pipeline Lead - Red New Service	S	plastic rise
		P/S Pipeline Lead White Existing Main	E	