

LOCATION 1576 Elkhead Cir. CITY Cartersville

BETWEEN Holtman Rd. STREET &  STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	120'	10-17-00		
MAIN TO PROP LINE	3/4"	P	45'			
PROP LINE TO BLDG	3/4"	P	75'			

ENTERS 1576 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI  INCHES W C LOCATION 365' SE. of center of Elkhead Cir.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C I  BARE STEEL  COATED STEEL  PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION 19' SE. of center of Elkhead Cir.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 955283

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

