

LOCATION 1579 Elkheart Cir. CITY Boston

BETWEEN Old Well Ln. STREET & Colony Woods Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>55'</u>	<u>12-12-07</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>5'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>50'</u>	<u>"</u>		

ENTERS 1579 BRANCHED INTO Ø

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 385' west of center of Elkheart Cir.


PRESSURE TEST @ 100 PSI FOR 14 HRS BY D. W. Woody

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH 3' FT 0" IN LOCATION 20' south of center of Elkheart Cir.

"A" P/S READING 12.17 TOTAL ANODES 1# Ø 17# Ø LR # A0667380

REMARKS new Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>service</u>