

LOCATION 1615 Elkhead Cir. CITY Gastonia

BETWEEN Elkhead Cir. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>110'</u>	<u>2-25-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>45'</u>			

ENTERS 1615 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES WC LOCATION 219' E of center of Elkhead Cir.


PRESSURE TEST @ 100 PSI FOR 4 HRS BY S.H.

MAIN-SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 20' N. of center of Elkhead Cir.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 135037

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	