


LOCATION 1627 Elkhart Cir CITY Gastonia
 BETWEEN Old Well Ln. STREET & Colony Woods Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>84'</u>	<u>1-17-2001</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>8'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>76'</u>	<u>"</u>		

 ENTERS 1627 Elkhart Cir. BRANCHED INTO D
 TAP SIZE 1/2" PRESSURE 60 PSI INCHES W C LOCATION 333' EAST
of center of Elkhart Cir.
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY P.C.
 MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998
 DEPTH 2' FT 6" IN LOCATION 34' south of center of Elkhart Cir.
 "A" P/S READING N/A TOTAL ANODES 1# D 17# D LR # 00017268
 REMARKS new 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	riser