

LOCATION 306 & 308 ELLABEE CITY GAST.
BETWEEN RANKIN STREET & DEAD END STREET

	SIZE	TYPE	306 LENGTH	308	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>59'</u>	<u>42'</u>		<u>6-3</u>	<u>-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>54'</u>	<u>42'</u>			

ENTERS: 306 BRANCHED INTO: 308

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION N. of 306
S. of 308


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GOL

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 96

DEPTH: 3 FT IN. LOCATION E. of ELLABEE

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY