

LOCATION 406 &amp; 408 S. EMERSON

CITY GASTONIA

BETWEEN GARRISON

STREET &amp; 4th

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	32'	11-5-94	tiered over 71' of 3/4" w	
MAIN TO PROP. LINE					Sec. to Ext 2" P. Main	
PROP. LINE TO BLDG.						

ENTERS: 406

BRANCHED INTO: 408

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION

14' W. of C of  
S. Emerson

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By AP

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 3 Ft. 0 In.

LOCATION


"A" P/S READING

P

TOTAL ANODES 1# 1 17#

L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	1.20
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY