

LOCATION 410 & 412 Emerson St CITY CASD

BETWEEN Emerson Blvd STREET & 4th STREET

	SIZE	TYPE	410' ENDS	412'	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	131'	51'			9-23-93
MAIN TO PROP LINE	3/4"	P	36'	27'			
PROP LINE TO BLDG	3/4"	P	95'	24'			

ENTERS: 410 Emerson St BRANCHED INTO: 412 Emerson St

TAP SIZE: 1/2 PRESSURE 60 P S I INCHES W C LOCATION 249' N of 4th


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs By J. Emure

MAIN - SIZE 2" C I      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In LOCATION 18' W of Emerson St

"A" P/S READING P TOTAL ANODES I #      I7 #      L.R. #     

REMARKS:     



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	