

LOCATION 417 S. Emerson

CITY Gastonia

BETWEEN Garrison

STREET & 4th

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	8'	11-5-94	trial over 94' of 3/4" w	
MAIN TO PROP. LINE					Sec. to Ext 2" P. Main	
PROP. LINE TO BLDG.						

ENTERS: 417

BRANCHED INTO: —

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 17' W. of Cap
S. Emerson


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By AP

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 3 Ft. 0 In. LOCATION

"A" P/S READING TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	SR	1.10
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY