

LOCATION 2330 Erika Ln. CITY Gastonia

BETWEEN Hampton brake Dr. STREET & Cat. de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	111'	11-5-98		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	101'			

ENTERS: 2330 BRANCHED INTO:

TAP SIZE. 1/2 PRESSURE 60 PSI INCHES W C LOCATION 275' N. of center of Hampton brake Dr.


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY S H

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED

DEPTH 3 FT. 0 IN LOCATION 10' NE. of center of Erika Ln.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 2155969

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY