

LOCATION 2420 Essen Dr. CITY Gastonia

BETWEEN Alpine Dr. STREET & LeRoy St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>102'</u>	<u>1-15-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>72'</u>			

ENTERS. 2420 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 294' W. of center of

Alpine Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Hufschmidt

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1988

DEPTH: 3 FT 0 IN LOCATION 12' S. of center of Essen Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 18868

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY