

LOCATION 1139 ESSEX AVE CITY GAST.
BETWEEN Apple Blossom Circle STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>72'</u>		<u>9-19</u>	<u>-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>67'</u>			

ENTERS: 1139 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION E. of 1139

PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GK
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 96
DEPTH: 3 FT. IN. LOCATION S. of ESSEX AVE

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead --Red New Service	<u>S</u>	<u>P</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		