

LOCATION 1211 + 1211 1/2 ESSEX AVE

CITY GASTONIA

BETWEEN Apple Blossom

STREET &amp; SCRUGGS

STREET

	SIZE	TYPE	1211 LENGTH 1211 1/2	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	A	TIED OVER	3-13-97		
MAIN TO PROP. LINE			(84) (100')			
PROP. LINE TO BLDG.			EXIST 3/4" P			

ENTERS: 1211

BRANCHED INTO:

TAP SIZE. 3/4

PRESSURE 100

PSI

INCHES W.C.

LOCATION 12' S OF ESSEX

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M Parker

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 96


DEPTH: 3 FT. 0 IN. LOCATION 328' W OF Apple Blossom

"A" P/S READING

TOTAL ANODES 1# 17#

L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P-risers
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY