

LOCATION 1335 Essex Ave. CITY Gastonia  
BETWEEN Vance St. STREET & Scruggs St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>30'</u>	<u>1-4-2001</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>20'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>10'</u>			

ENTERS 1335 Essex Ave. BRANCHED INTO 1324 Essex Ave.  
TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 92' East of center of scruggs st.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D.R.

MAIN SIZE 3/4" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1995

DEPTH 2' FT 0" IN LOCATION 67' south of center of Essex Ave.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 1204386

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>