

LOCATION 412 + 420 Evergreen ST.CITY Gastonia.BETWEEN Melvin Dr.STREET & Willimax AVE.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.						
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS:


BRANCHED INTO:

TAP SIZE:

PRESSURE _____ PSI _____ INCHES W.C.

LOCATION

PRESSURE TEST: @ _____ PSI FOR _____ HRS. BY _____

MAIN-SIZE 3" C.I. Ø BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1958DEPTH: 3' FT. Ø IN. LOCATION Evergreen ST."A" P/S READING 1.714 TOTAL ANODES 1# _____ 17# _____ L.R. # _____REMARKS: Bond insulators on existing 3/4" C+W 1/2 service lines, also bonded existing 3/4" C+W 1/2 service line to 2" C+W gas main. C.P. # 01872Readings: #412: 1.075 before bonds + 1.790 after bonds were made.#420: 1.002 before bonds + 1.750 after bonds were made.

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY