

LOCATION 428 & 436 Evergreen ST. CITY Gastonia,
BETWEEN Willimax Ave. STREET & Melvin Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.						
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						


ENTERS: BRANCHED INTO:
TAP SIZE: PRESSURE _____ PSI _____ INCHES W.C. LOCATION

PRESSURE TEST: @ _____ PSI FOR _____ HRS. BY _____
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1958
DEPTH: 3' FT. 0" IN. LOCATION Evergreen ST.

"A" P/S READING 1.896 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Bonded insulated 3/4" C+W service tee to existing 3/4" C+W service line, also bonded 3/4" C+W service line to 2" C+W gas main. C.P. # 01872.

Readings: #428 Evergreen: .350 before bond & 1.850 after bonds were made.
#436 Evergreen: .0175 before bond & 1.890 after bonds were made.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY