

LOCATION 1005 Fair Field Dr.

CITY Gastonia

BETWEEN Picadilly Circle

STREET & Edgemont Ave

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	3'	6-18-94	Tied over	125' Existing
MAIN TO PROP. LINE					3/4 CFW	
PROP. LINE TO BLDG.						

ENTERS: 1005

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 334' E of Cof Edgemont Ave

PRESSURE TEST: @ 100 psi For 4 Hrs. By RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993


DEPTH: 3 Ft. 0 In. LOCATION 15' S of Cof Fair Field Dr.

"A" P/S READING Plastic TOTAL ANODES 1* 1 17* L.R. #

REMARKS:

Bare Main Replacement
Program

P.S. Reading WAS .04 Came up to .90 after Anode.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser .90
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY