

LOCATION 1008 Fairfield DR CITY Gastonia

BETWEEN Picadilly STREET & Clinton STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>91'</u>	<u>10-8-98</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>11</u>	<u>5'</u>			
PROP. LINE TO BLDG	<u>1"</u>	<u>11</u>	<u>86</u>			

ENTERS: 1008 BRANCHED INTO: -

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 23' S. of C of

FAIRFIELD


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY _____

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1992

DEPTH 3 FT 0 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY