

LOCATION 1075 Fairfield dr CITY Gastonia
BETWEEN Clinton STREET & Piccadilly STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>125'</u>	<u>12-4-98</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>27'</u>			
PROP LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>48</u>			

ENTERS: 1011 BRANCHED INTO: 1075

TAP SIZE. 1/2 PRESSURE _____ PSI _____ INCHES W C LOCATION 27' N. of C of Fairfield


PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY GP

~~MAIN~~ SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 8-1-80

DEPTH: 1 FT 6 IN. LOCATION _____

"A" P/S READING 1.40 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY