

LOCATION 1091 Fairfield Dr CITY Gastonia

BETWEEN Clinton Dr- STREET & Maple St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>80'</u>	<u>4-10-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>70'</u>			

ENTERS: 1091 BRANCHED INTO:

TAP SIZE 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 128' W. of center of

Clinton Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Huffstetter

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_

DEPTH 3 FT. 0 IN. LOCATION 19' N. of center of Fairfield Dr

"A" P/S READING 1.5 TOTAL ANODES 1# 0 17# 0 L.R. # 227589

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY