

LOCATION 1205 FairField Dr. CITY GASTONIA  
BETWEEN Carlton STREET & Maple STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>139'</u>	<u>5-12-97</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>132'</u>			

ENTERS: 1205 BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 231' E of (of) Carlton

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1991  
DEPTH: \_\_\_\_\_ FT. \_\_\_\_\_ IN LOCATION 10" S of (of) FairField Dr.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 275299

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY