

LOCATION 1702 Fairfield

CITY Gastonia

BETWEEN Fairfield

STREET & Hawthorne

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	18'	7-2-94	Tied over 72' ^{Exist.} 3/4 Ctlw	
MAIN TO PROP. LINE					to Existing	2" Plastic
PROP. LINE TO BLDG.					Main	

ENTERS: 1702

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 64' N of C of Fairfield


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BC

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. In. LOCATION 16' W of C of Fairfield Dr

"A" P/S READING Plastic TOTAL ANODES 1* - 17* - L.R. #

REMARKS: Tied wire off at Main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	Riser	1.4
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY